



MATERIALS TESTING, INC.

55 LAURA STREET • NEW HAVEN, CONNECTICUT 06512 • (203)468-5216
42 BOSTON POST ROAD • WILLIMANTIC, CONNECTICUT 06226 • (860)423-1972
materialstestinginc.com


DATE: 07-01-2024

REPORT: S-1008

CLIENT: DeFeo Materials, LLC
100 Bank Street, Suite 205
Seymour, CT 006483
Attn: Mr. Christopher DeFeo

PROJECT: Client Information

SUBJECT: SIEVE ANALYSIS (ASTM C-136)



Material: 1-1/4" Processed
Source: Stockpile - On-Site, Crusher Run
Received: 06-28-2024

Lab Sample No.: L-9077
Sampled by: Client

SIEVE SIZE	PERCENT PASSING	STATE OF CT M.02.06 A	STATE OF CT M.02.06 C	STATE OF CT M.05.01
3½" (90mm)	100	100		
3" (75mm)	100			
2½" (63mm)	100			100
2" (50mm)	100			95 - 100
1½" (37.5mm)	100	55 - 100	100	
1" (25mm)	96			
¾" (19mm)	74		45 - 80	50 - 75
½" (12.5mm)	46			
⅜" (9.5mm)	35			
¼" (6.3mm)	26	25 - 60	25 - 60	25 - 45
#4 (4.75mm)	23			
#10 (2.0mm)	16	15 - 45	15 - 45	
#20 (850µm)	13			
#40 (425µm)	11	5 - 25	5 - 25	5 - 20
#100 (150µm)	5	0 - 10	0 - 10	2 - 12
#200 (75µm)	3.3	0 - 5	0 - 5	

This material as sampled and delivered meets the listed specifications.

Materials Testing, Inc.

Bryan R. Kearns

Bryan R. Kearns

1cc: C. DeFeo

adi